


City of Abbotsford Water Distribution System

Recent Water Quality Results

Updated: 2023-10-13 11:44

Sample Locations



- Refer to following pages for results.
- Water quality parameter descriptions on last page.

Week A

Southeast Route - E02, E07, E09, E10, E11, E12, E13, E14, E17, E18, W02, W03

Northwest Route - W01, W04, W05, W07, W11, W13, W15, W16, W19, W21, W23, W34

Week B

Southeast Route - E07, E08, E09, E12, E13, E15, E16, E18, E21, E23, W02, W03

Northwest Route - W01, W04, W06, W07, W11, W13, W15, W16, W19, W21, W23, W34

Each week is tested biweekly.

Questions?

City of Abbotsford Engineering

604-864-5511

eng-info@abbotsford.ca

City of Abbotsford Water Distribution System

Recent Water Quality Results

Updated: 2023-10-13 11:44

	Turbidity	Total Chlorine	Total Coliforms (counts)	E.coli (counts)
Units	NTU	mg/L	CFU/100mL	CFU/100mL
E02 - 310 Arnold Road				
September 12	0.44	1.25	0	0
September 26	0.38	1.16	0	0
E07 - 6230 Tolmie Road				
September 6	<0.10	0.41	0	0
September 12	0.31	0.44	0	0
September 19	0.15	0.65	0	0
September 26	0.48	0.63	0	0
E08 - 3434 McDermott Road				
September 6	0.10	0.73	0	0
September 19	0.20	0.84	0	0
E09 - 36232 Lower Sumas Mountain Road				
September 6	0.12	1.18	0	0
September 12	0.22	1.30	0	0
September 19	0.20	1.22	0	0
September 26	0.43	1.11	0	0
E10 - 36101 Regal Parkway				
September 12	0.25	1.48	0	0
September 26	0.55	1.68	0	0
E11 - 2598 St. Moritz Way				
September 12	0.36	1.25	0	0
September 26	0.23	1.69	0	0
E12 - 2691 Beck Road				
September 6	<0.10	1.44	0	0
September 12	0.35	1.42	0	0
September 19	0.22	1.35	0	0
September 26	0.18	1.44	0	0
E13 - 2087 McMillan Road				
September 6	<0.10	1.34	0	0
September 12	0.40	1.36	1.0*	0
September 15	0.15	1.41	0	0
September 19	0.12	1.42	0	0
September 26	0.29	1.51	0	0
E14 - 2211 Mouldstade Road				
September 12	0.21	1.24	0	0
September 26	0.23	1.35	0	0

City of Abbotsford Water Distribution System

Recent Water Quality Results

Updated: 2023-10-13 11:44

	Turbidity	Total Chlorine	Total Coliforms (counts)	E.coli (counts)
Units	NTU	mg/L	CFU/100mL	CFU/100mL
E15 - 2215 Orchard Drive				
September 6	0.15	1.42	0	0
September 19	0.15	1.61	0	0
E16 - 2540 Eagle Mountain Drive				
September 6	0.18	1.45	0	0
September 19	0.27	1.24	0	0
E17 - 2720 St. Moritz Way				
September 12	0.19	1.31	0	0
September 26	0.32	1.33	0	0
E18 - 36321 Vye Road				
September 6	<0.10	1.31	0	0
September 12	0.19	1.47	0	0
September 19	0.42	1.46	0	0
September 26	0.49	1.25	0	0
E21 - 34694 5th Avenue				
September 6	<0.10	1.19	0	0
September 19	0.53	1.44	0	0
E23 - 36026 Village Knoll				
September 6	<0.10	1.29	0	0
September 19	0.16	1.46	0	0
W01 - 35041 Harris Road				
September 6	0.19	1.40	0	0
September 12	0.15	1.57	0	0
September 19	0.22	1.32	0	0
September 26	0.18	1.64	0	0
W02 - 3836 Old Clayburn Road				
September 6	0.11	1.55	0	0
September 12	0.27	1.62	0	0
September 19	0.12	1.29	0	0
September 26	0.16	1.56	0	0
W03 - 35944 McKee Road				
September 6	0.13	1.63	0	0
September 12	0.38	1.70	0	0
September 19	0.21	1.48	0	0
September 26	0.26	1.23	0	0

City of Abbotsford Water Distribution System

Recent Water Quality Results

Updated: 2023-10-13 11:44



	Turbidity	Total Chlorine	Total Coliforms (counts)	E.coli (counts)
Units	NTU	mg/L	CFU/100mL	CFU/100mL
W04 - 34638 Bateman Road				
September 6	0.16	1.17	0	0
September 12	0.23	1.18	0	0
September 19	0.25	1.35	0	0
September 26	0.20	1.20	0	0
W05 - 3315 Gladwin Road				
September 12	0.22	1.31	0	0
September 26	0.30	1.61	0	0
W06 - 32961 South Fraser Way				
September 6	0.10	1.34	0	0
September 19	0.16	1.26	0	0
W07 - 32111 Joyce Avenue				
September 6	0.11	1.33	0	0
September 12	0.49	1.32	0	0
September 19	0.13	1.36	0	0
September 26	0.13	1.27	0	0
W11 - 5030 Lefeuve Road				
September 6	0.20	0.99	0	0
September 12	0.22	1.20	0	0
September 19	0.21	1.28	0	0
September 26	0.15	1.31	0	0
W13 - 7942 Bradner Road				
September 6	0.16	0.67	0	0
September 12	0.26	0.76	0	0
September 19	0.23	1.42	0	0
September 26	0.20	1.44	0	0
W15 - 3154 Clearbrook Road				
September 6	0.17	1.56	0	0
September 12	0.12	1.53	0	0
September 19	0.16	1.51	0	0
September 26	0.24	1.57	0	0
W16 - 27875 Swensson Avenue				
September 6	0.13	1.20	0	0
September 12	0.22	1.18	0	0
September 19	0.25	1.17	0	0
September 26	0.21	1.21	0	0

City of Abbotsford Water Distribution System

Recent Water Quality Results

Updated: 2023-10-13 11:44



	Turbidity	Total Chlorine	Total Coliforms (counts)	E.coli (counts)
Units	NTU	mg/L	CFU/100mL	CFU/100mL
W19 - 4945 Mt. Lehman Road				
September 6	0.15	1.57	0	0
September 12	0.25	1.76	0	0
September 19	0.20	1.61	0	0
September 26	0.32	1.61	0	0
W21 - 2059 Peardonville Road				
September 6	0.12	0.84	0	0
September 12	0.26	1.31	0	0
September 19	0.25	1.13	0	0
September 26	0.37	1.08	0	0
W23 - 3612 Blue Jay Street				
September 6	0.22	1.40	0	0
September 12	0.18	1.34	0	0
September 19	0.24	1.36	0	0
September 26	0.36	1.41	0	0
W34 - 926 Columbia Street				
September 6	0.13	1.28	0	0
September 12	0.25	1.15	0	0
September 19	0.33	1.06	0	0
September 26	0.31	1.32	0	0
Blank Cell = No Data Collected				

City of Abbotsford Water Distribution System

Recent Water Quality Results

Updated: 2023-10-13 11:44



Parameter	Description	Acceptable Range
Turbidity	Suspended matter that interferes with the clarity of the water. While not a health concern itself, turbidity is an indicator of possible contamination.	There are no regulations for distribution system turbidity; water system operators aim for less than 1.0 NTU.
Total Chlorine	Used to monitor the level of disinfectant used to inactivate microorganisms such as bacteria and viruses.	There are no regulations for distribution system total chlorine; system operators aim to maintain a detectable residual. As long as there are no total coliforms, lower values are not a concern. Higher values are not deemed a health concern unless they exceed the World Health Organization's recommended limit of 5ppm.
Total Coliforms	A group of bacteria that generally do not cause human disease, but their presence in water may indicate possible contamination.	The BC Drinking Water Act stipulates that no more than 10% of samples during a 30-day period may be positive for Total Coliforms and that no single sample may contain more than 10 counts.
E. Coli	A member of the Total Coliform group and its presence in water indicates contamination.	The BC Drinking Water Act stipulates that no E.Coli should be detected in drinking water.

Note: Turbidity and Total Chlorine are measured with field instruments. Result trends are used as indicators of significant water quality changes; specific values are not necessarily accurate.

***Low TC count. Fraser Health is informed of all adverse results.**